

MOBILE FOOD VENDERS (TRUCK OR TRAILER OR TENT)

A – VENT HOODS (for exhaust systems)

- ❑ All hoods must be constructed of not less than No. 20 MSG (0.94mm) stainless steel or No. 18 MSG (1.09mm) steel. NO galvanized metal is acceptable. All seams and joints must be liquid tight.

B – FUEL SUPPLY FOR COOKING EQUIPMENT

- ❑ A qualified service department must certify all Fuel Fired Equipment **annually**. *The service company must supply a letter of certification.*
- ❑ Fuel tanks must be installed and protected in accordance with the Propane Handling and Utilization Code of Ontario.

C – FIRE PROTECTION

- ❑ All cooking that produces smoke or grease-laden vapors are to be equipped with the automatic fixed extinguishing systems installed and certified by qualified service technician and listed vent hood as required by N.F.P.A. 96.
- ❑ These systems must be serviced and tagged annually by a qualified service technician.
- ❑ At least one portable fire extinguisher of the proper rating and type must be installed in the vehicle.
- ❑ These extinguishers must be serviced and tagged annually by a qualified service technician.

D – EXITING

- ❑ A clear accessible exit from the interior of the vehicle must be maintained at all times. Means of egress must be kept clear at all times.

E – CLEANING

- ❑ All cooking equipment and ventilation equipment must be kept clean as required by N.F.P.A. 96.

F – TENTS

- ❑ Under the OBC, Building Permit is required for an individual or group of tents that covers more than 60 square meters (645 square feet) of ground. A tent that covers less than 60 square meters of ground but is within 3 meters of another structure or contains commercial cooking equipment also requires a Building Permit.
- ❑ Every tent and all tarpaulins and decorative materials used in connection with the structure shall conform to CAN/ULC-S109, "Flame Tests of Flame-Resistant Fabrics and Films.
- ❑ No cooking that produces grease/oily vapours will be permitted within 3 meters (10 feet) of tents or structures and must be safety away from the public.